



Clarification of tender No. 09/2016-2017: Proposed construction of 5No electric masts for Athi River EPZ, Machakos County

Document page/Clause	Clarification
Page 35	Amend to read as follows: <i>Proof of having completed at least 2 similar contracts of not less than Kshs 15 Million in value within last five(5)years</i>
Page 84, Bill No. 5, Part 5.1	Amend to read as follows: <i>with a life time of at least 50,000 hours</i>
Clarification on height of Mast	The height of the mast as per the BQ's is 20 Metres