



TENDER NO. 04/2022-2023: PROPOSED SUPPLY, DELIVERY, INSTALLATION AND TESTING OF CARPORT SOLAR PLANT IN ATHI RIVER EPZA HEAD OFFICE

CLARIFICATION

1. Item No. 4.2: The AC cable is 35 mm squared 4 core.